Send original copy certified mail to: TNRCC, P.O. Box 13087, Austin, TX 78711-3087 — Please use black ink.

ATTENTION OWNER: *Confidentiality Privilege Notice on Reverse Side*

State of Texas WELL REPORT

Texas Water Well Drillers Advisory Council
P.O. Box 13087
Austin, TX 78711-3087
512-239-0530

1) OWNER E.O.L. Water Supply Corp. (Name) ADDRESS (Street or RFD) Axtell (City) TX (State) 76624 (Zip)

2) ADDRESS OF WELL: County McLennan; Elk Hwy. (Street, RFD or other) Waco (City) TX (State) (Zip); GRID # 39-25-1

3) TYPE OF WORK (Check): [X] New Well [ ] Deepening [ ] Reconditioning [ ] Plugging

4) PROPOSED USE (Check): [ ] Monitor [ ] Environmental Soil Boring [ ] Domestic [ ] Industrial [ ] Irrigation [ ] Injection [X] Public Supply [ ] De-watering [ ] Testwell
If Public Supply well, were plans submitted to the TNRCC? [ ] Yes [ ] No

5) 

6) WELL LOG:
Date Drilling: Started 4-9 19 98 Completed 7-10 19 98

DIAMETER OF HOLE

Dia. (in.)	From (ft.)	To (ft.)
14 3/4"	Surface	2910

7) DRILLING METHOD (Check): [ ] Driven [ ] Air Rotary [X] Mud Rotary [ ] Bored [ ] Air Hammer [ ] Cable Tool [ ] Jetted [ ] Other

From (ft.)	To (ft.)	Description and color of formation material
0	410	Gray Shale
410	665	White Lime
665	1040	Gray Shale
1040	1570	Lmy Shale
1570	2265	Sdy Shale w/Lm Strks
2265	2370	Gray Shale
2370	2405	Lmy Sand
2405	2488	Gray Shale
2488	2502	Lime
2502	2563	Gray Lmy Shale
2563	2670	Lmy Sand
2670	2790	Gray Lmy Shale
2790	2845	Lmy Sand
2845	2910	Red Chert See

(Use reverse side if necessary) 10PD

8) Borehole Completion (Check): [ ] Open Hole [ ] Straight Wall [ ] Underreamed [ ] Gravel Packed [X] Other Perforated
If Gravel Packed give interval ... from _____ ft. to _____ ft.

CASING, BLANK PIPE, AND WELL SCREEN DATA:

Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.) From	Setting (ft.) To	Gage Casting Screen
10	N	J-55 Steel Casing	+2	2907	40.5#
1/2		Perforations	2563	2836	1/2 holes

9) CEMENTING DATA [Rule 338.44(1)]
Cemented from 2907 ft. to 0 ft. No. of sacks used 885
_____ ft. to _____ ft. No. of sacks used _____
Method used Circulated from bottom to top
Cemented by Pumpco Services
Distance to septic system field lines or other concentrated contamination 1320 ft.
Method of verification of above distance Measured

10) SURFACE COMPLETION
[X] Specified Surface Slab Installed [Rule 338.44(2)(A)]
[ ] Specified Steel Sleeve Installed [Rule 338.44(3)(A)]
[ ] Pitless Adapter Used [Rule 338.44(3)(b)]
[ ] Approved Alternative Procedure Used [Rule 338.71]

11) WATER LEVEL:
Static level 475 ft. below land surface Date 7-10-98
Artesian flow _____ gpm. Date _____

12) PACKERS: Type Depth

13) TYPE PUMP:
[ ] Turbine [ ] Jet [X] Submersible [ ] Cylinder
[ ] Other _____
Depth to pump bowls, cylinder, jet, etc., 1175 ft.

14) WELL TESTS:
Type test: [X] Pump [ ] Bailer [ ] Jetted [ ] Estimated
Yield: 250 gpm with 520 ft. drawdown after 36 hrs.

15) WATER QUALITY:
Did you knowingly penetrate any strata which contained undesirable constituents?
[ ] Yes [X] No If yes, submit "REPORT OF UNDESIRABLE WATER"
Type of water? _____ Depth of strata _____
Was a chemical analysis made? [ ] Yes [ ] No

FILE ID SEC

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. I understand that failure to complete items 1 thru 15 will result in the log(s) being returned for completion and resubmittal.

EMP # 27411 DESC CC 10-30

COMPANY NAME Jimmy Jack Biffle (Type or print) WELL DRILLER'S LICENSE NO. _____

ADDRESS P. O. Drawer L (Street or RFD) Muenster (City) Texas (State) 76252 (Zip)

(Signed) _____ (Licensed Well Driller)

(Signed) _____ (Registered Driller Trainee)

Please attach electric log, chemical analysis, and other pertinent information, if available. 39-25-103

TNRCC-0199 (Rev. 11-01-94)