

Please use black ink.
 Send original copy by certified mail to the Texas Department of Water Resources P. O. Box 13087 Austin, Texas 78711

State of Texas
WATER WELL REPORT

Texas Water Well Drillers Board
 P. O. Box 13087
 Austin, Texas 78711

ATTENTION OWNER: Confidentiality Privilege Notice on Reverse Side

1) OWNER HARRICK WSC (Name) Address _____ (Street or RFD) _____ (City) _____ (State) _____ (Zip)
 2) LOCATION OF WELL: County 1112 miles in NW direction from Waco (Town)
 (N.E., S.W., etc.)

Legal description:
 Section No. _____ Block No. _____ Township _____
 Abstract No. _____ Survey Name _____
 Distance and direction from two intersecting section or survey lines _____
 See attached map.

3) TYPE OF WORK (Check):
 New Well Deepening Reconditioning Plugging
 4) PROPOSED USE (Check):
 Domestic Industrial Public Supply Irrigation Test Well Other _____
 5) DRILLING METHOD (Check):
 Mud Rotary Air Hammer Driven Bored Air Rotary Cable Tool Jetted Other _____

6) WELL LOG:
 Date drilled 4/14/89
 DIAMETER OF HOLE

Dia. (in.)	From (ft.)	To (ft.)
12 1/2	Surface	35
8 3/4		1322

 7) BOREHOLE COMPLETION:
 Open Hole Straight Wall Underreamed
 Gravel Packed Other _____
 If Gravel Packed give interval ... from _____ ft. to _____ ft.

From (ft.)	To (ft.)	Description and color of formation material	Dia. (in.)	New or Used	Steel, Plastic, etc. Perf., Slotted, etc. Screen Mfg., if commercial	Setting (ft.)	Gage Casing Screen
						From	To
0	10	TOP SOIL					
10	25	gray & blue clay	12 1/2	U	5144	0	35
25	464	yellow G.S. clay & sh.	8 3/4	M	"	0	1322
464	490	clay					
490	1018	clay & shale					
1018	1113	clay					
1113	1160	clay sh.					
1160	1267	clay					
1267	1320	clay					
1320	1323	yellow sh.					

9) CEMENTING DATA [Rule 319.44(b)]
 Cemented from 0 ft. to 1320 ft.
 Method used Pressure
 Cemented by 4 MEADOWS

10) SURFACE COMPLETION
 Specified Surface Slab Installed [Rule 319.44(c)]
 Pitless Adapter Used [Rule 319.44(d)]
 Approved Alternative Procedure Used [Rule 319.71]

RECEIVED
 NOV 29 1989

11) WATER LEVEL:
 Static level 355 ft. below land surface Date 9/89
 Artesian flow _____ gpm. Date _____

12) PACKERS: Type _____ Depth _____

13) TYPE PUMP:
 Turbine Jet Submersible Cylinder
 Other _____
 Depth to pump bowls, cylinder, jet, etc., 672 ft.

15) WATER QUALITY:
 Did you knowingly penetrate any strata which contained undesirable water? Yes No
 If yes, submit "REPORT OF UNDESIRABLE WATER"
 Type of water? _____ Depth of strata _____
 Was a chemical analysis made? Yes No

14) WELL TESTS:
 Type Test: Pump Bailer Jetted Estimated
 Yield: 83 gpm with 30 ft. drawdown after 36 hrs.

I hereby certify that this well was drilled by me (or under my supervision) and that each and all of the statements herein are true to the best of my knowledge and belief. I understand that failure to complete items 1 thru 12 will result in the log(s) being returned for completion and resubmittal.

COMPANY NAME MEADOWS DRILLING Water Well Driller's License No. 1494
 ADDRESS 6611 SANGRE (City) WACO (State) TX (Zip) 76710
 (Signed) J. Meadows (Licensed Water Well Driller) (Signed) _____ (Registered Driller Trainee)
 Please attach electric log, chemical analysis, and other pertinent information, if available. For TDWR use only Well No. 40-23-4 Located on map _____